Features

- 1-channel signal conditioner
- 24 V DC supply (Power Rail)
- Scaleable current or voltage input
- · Current or voltage output
- · Relay contact output
- · Configurable by keypad
- · Line fault detection (LFD)

Function

This signal conditioner is suitable for the connection of current and voltage signals and provides isolation for non-intrinsically safe applications.

The input ranges include 0 mA ... 20 mA, 0 V ... 10 V or 0 mV ... 60 mV. Subranges from the input ranges are selectable.

The output measuring signals are 0/4 mA ... 20 mA, 0/2 V ... 10 V or 0/1 V ... 5 V.

The output relay serves as trip value contact.


On the display the measured value can be indicated in various physical units.

The unit is easily programmed by the use of a keypad located on the front of the unit.

For additional information, refer to the manual and www.pepperl-fuchs.com.


Assembly

Front view



 $C \in$

Connection



General specifications	
Signal type	Analog input
Supply	
Connection	terminals 14+, 15- or Power Rail
Rated voltage U _r	20 30 V DC
-	≤ 80 mA DC
Rated current I _r	
Power consumption	≤ 1.6 W
Input	
Connection side	field side
Connection	terminals 1+, 3-: mV, V; terminals 2+, 3-: mA
Input resistance	voltage: 1 M Ω , current: \leq 100 Ω
Limit	30 V
Current	0 20 mA
Voltage	0 10 V / 0 60 mV
Resolution	15 Bit
Output	
Connection side	control side
Connection	output I: terminals 10, 11, 12
	output II: terminals 7-, 8+, 9-
Output I	signal, relay
Contact loading	250 V AC/2 A/cos φ 0.7; 40 V DC/2 A
Mechanical life	2 x 10 ⁷ switching cycles
Energized/De-energized delay	approx. 10 ms / approx. 10 ms
Output II	analog
Load	current: \leq 550 Ω , voltage: \geq 1 k Ω
Analog voltage output	0/1 5 V , 0/2 10 V
Analog current output	0/4 20 mA
Transfer characteristics	0/4 20 HIA
	0.4.0/ of full people value
Deviation	0.1 % of full-scale value
Resolution/accuracy	current: 1 μ A/20 μ A voltage: 0.5 mV/10 mV mV: 3 μ V/60 μ V
Influence of ambient temperature	0.003 %/K (30 ppm)
Reaction time	≥ 150 ms/≤ 300 ms
Galvanic isolation	
Input/Output	reinforced insulation according to IEC 61140, rated insulation voltage 300 V _{eff}
Input/power supply	reinforced insulation according to IEC 61140, rated insulation voltage 300 V _{eff}
Output/power supply	reinforced insulation according to IEC 61140, rated insulation voltage 300 V _{eff}
Indicators/settings	en
Display elements	display
Control elements	Control panel
	· ·
Configuration	via operating buttons
Labeling	space for labeling at the front
Directive conformity	
Electromagnetic compatibility	
Directive 2004/108/EC	EN 61326-1:2006
Low voltage	
Directive 2006/95/EC	EN 50178:1997
Conformity	
Electromagnetic compatibility	NE 21
Degree of protection	IEC 60529
Protection against electrical shock	IEC 61140
Ambient conditions	
Ambient temperature	-20 60 °C (-4 140 °F)
Mechanical specifications	
Degree of protection	IP20
Connection	screw terminals
Mass	150 g
Dimensions	
	20 x 119 x 115 mm (0.8 x 4.7 x 4.5 inch) , housing type B3
Mounting Congress information	on 35 mm DIN mounting rail acc. to EN 60715:2001
General information	
Supplementary information	Observe the certificates, declarations of conformity, instruction manuals, and manuals where applicable. For information see www.pepperl-fuchs.com.



Accessories

Power feed module KFD2-EB2

The power feed module is used to supply the devices with 24 V DC via the Power Rail. The fuse-protected power feed module can supply up to 150 individual devices depending on the power consumption of the devices. Collective error messages received from the Power Rail activate a galvanically-isolated mechanical contact.

Power Rail UPR-03

The Power Rail UPR-03 is a complete unit consisting of the electrical insert and an aluminium profile rail 35 mm x 15 mm. To make electrical contact, the devices are simply engaged.

Profile Rail K-DUCT with Power Rail

The profile rail K-DUCT is an aluminum profile rail with Power Rail insert and two integral cable ducts for system and field cables. Due to this assembly no additional cable guides are necessary.



Power Rail and Profile Rail must not be fed via the device terminals of the individual devices!